

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100 mL	Total Coliform CFU/100 mL	Back CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	---	02-Feb-05	02-Feb-05	02-Feb-05	02-Feb-05
2: Analysis Start Time		---	---	16:00	16:00	16:00	15:30
3: Analysis Approval Date		---	---	03-Feb-05	03-Feb-05	03-Feb-05	04-Feb-05
4: Analysis Approval Time		---	---	14:00	14:00	14:00	13:30
5: MAC		---	---	0	0	200	500
6: RW - Pumphouse Raw	01-Feb-05 09:10	4.6	---	0	0	0	---
7: TW - Distribution Lot # 48	01-Feb-05 09:19	4.6	0.3	0	0	0	< 10

---