

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Free Chlorine mg/L | E.Coli CFU/100mL | Total Coliform CFU/100mL | Background CFU/100 mL | HPC CFU/1mL Spread Plate |
|---------------------------------------|--------------------|-----------------------------|--------------------|------------------|--------------------------|-----------------------|--------------------------|
| 1: Analysis Start Date | | --- | --- | 03-Aug-05 | 03-Aug-05 | 03-Aug-05 | 03-Aug-05 |
| 2: Analysis Start Time | | --- | --- | 14:20 | 14:20 | 14:20 | 12:40 |
| 3: Analysis Approval Date | | --- | --- | 05-Aug-05 | 05-Aug-05 | 05-Aug-05 | 05-Aug-05 |
| 4: Analysis Approval Time | | --- | --- | 12:37 | 12:37 | 12:37 | 12:37 |
| 5: MAC | | --- | --- | 0 | 0 | 200 | 500 |
| 6: RW - Pumphouse Raw | 02-Aug-05 09:07 | 6.9 | --- | 0 | 0 | 0 | --- |
| 7: DW - Treated Distribution (Lot 48) | 02-Aug-05 09:15 | 6.9 | 0.5 | 0 | 0 | 0 | < 10 |