

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	E.Coli CFU/100 mL	Total Coliform CFU/100 mL	Back CFU/100 mL	HPC CFU/1mL Spread Plate
1: *Approved Date		---	---	03-Nov-04	03-Nov-04	03-Nov-04	03-Nov-04
2: *Approved Time		---	---	12:30	12:30	12:30	11:40
3: MAC		---	---	0	0	200	500
4: DW - Lot #48	02-Nov-04 08:51	6.7	0.40	0	0	0	10 <