

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100mL	Total Coliform CFU/100mL	Background CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	---	02-Nov-05	02-Nov-05	02-Nov-05	02-Nov-05
2: Analysis Start Time		---	---	16:35	16:35	16:35	15:55
3: Analysis Approval Date		---	---	04-Nov-05	04-Nov-05	04-Nov-05	04-Nov-05
4: Analysis Approval Time		---	---	15:13	15:13	15:13	15:13
5: MAC		---	---	0	0	200	500
6: RW-Pumphouse	01-Nov-05 08:51	6.1	0.4	0	0	0	---
7: DW-Lot 48	01-Nov-05 09:01	6.1	0.4	0	0	0	< 10