

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100 mL	Total Coliform CFU/100 mL	Back CFU/100 mL	HPC CFU/1mL Spread Plate
1: *Approved Date		---	---	05-Jan-05	05-Jan-05	05-Jan-05	05-Jan-05
2: *Approved Time		---	---	16:30	16:30	16:30	14:40
3: MAC		---	---	0	0	200	500
4: RW - Pumphouse Raw	04-Jan-05 08:55	3.9	---	0	2	19	
TW - Distribution (lot 48)	04-Jan-05 09:05	3.9	0.4	0	0	0	80