

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Free Chlorine mg/L | E.Coli CFU/100mL | Total Coliform CFU/100mL | Background CFU/100 mL | HPC CFU/1mL Spread Plate |
|---------------------------|--------------------|-----------------------------|--------------------|------------------|--------------------------|-----------------------|--------------------------|
| 1: Analysis Start Date | | --- | --- | 05-Oct-05 | 05-Oct-05 | 05-Oct-05 | 05-Oct-05 |
| 2: Analysis Start Time | | --- | --- | 16:25 | 16:25 | 16:25 | 14:05 |
| 3: Analysis Approval Date | | --- | --- | 08-Oct-05 | 08-Oct-05 | 08-Oct-05 | 08-Oct-05 |
| 4: Analysis Approval Time | | --- | --- | 11:36 | 11:36 | 11:36 | 11:36 |
| 5: MAC | | --- | --- | 0 | 0 | 200 | 500 |
| 6: RW-Pumphouse | 04-Oct-05 08:30 | 9.0 | --- | 0 | 0 | 2 | --- |
| 7: DW-Lot 48 | 04-Oct-05 08:38 | 9.0 | 0.5 | 0 | 0 | 0 | < 10 |