

## CERTIFICATE OF ANALYSIS

### Final Report

<b>Sample ID</b>	<b>Sample Date &amp; Time</b>	<b>Temperature Upon Receipt °C</b>	<b>Free Chlorine mg/L</b>	<b>E.Coli CFU/100 mL</b>	<b>Total Coliform CFU/100 mL</b>	<b>Back CFU/100 mL</b>	<b>HPC CFU/1mL Spread Plate</b>
1: *Approved Date		---	---	08-Dec-04	08-Dec-04	08-Dec-04	08-Dec-04
2: *Approved Time		---	---	16:20	16:20	16:20	15:30
3: MAC		---	---	0	0	200	500
4: RW - Pumphouse	07-Dec-04 08:26	8.0	---	0	1	4	
DW - Lot 48	07-Dec-04 08:40	8.0	0.5	0	0	0	10