

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Free Chlorine mg/L | E.Coli CFU/100mL | Total Coliform CFU/100mL | Background CFU/100 mL | HPC CFU/1mL Spread Plate |
|---------------------------|--------------------|-----------------------------|--------------------|------------------|--------------------------|-----------------------|--------------------------|
| 1: Analysis Start Date | | --- | --- | 15-Feb-06 | 15-Feb-06 | 15-Feb-06 | 15-Feb-06 |
| 2: Analysis Start Time | | --- | --- | 14:40 | 14:40 | 14:40 | 14:10 |
| 3: Analysis Approval Date | | --- | --- | 17-Feb-06 | 17-Feb-06 | 17-Feb-06 | 17-Feb-06 |
| 4: Analysis Approval Time | | --- | --- | 12:32 | 12:32 | 12:32 | 12:32 |
| 5: MAC | | --- | --- | 0 | 0 | 200 | 500 |
| 6: RW-Pumphouse | 14-Feb-06 08:39 | 5.0 | --- | 0 | 0 | 0 | --- |
| 7: DW-Lot 48 | 14-Feb-06 08:44 | 5.0 | 0.4 | 0 | 0 | 0 | < 10 |