

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100mL	Total Coliform CFU/100mL	Background CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	---	16-Nov-05	16-Nov-05	16-Nov-05	16-Nov-05
2: Analysis Start Time		---	---	14:55	14:55	14:55	10:50
3: Analysis Approval Date		---	---	18-Nov-05	18-Nov-05	18-Nov-05	18-Nov-05
4: Analysis Approval Time		---	---	10:08	10:08	10:08	10:08
5: MAC		---	---	0	0	200	500
6: DW-Lot 48	15-Nov-05 09:20	10.4	0.5	0	0	0	< 10