

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100mL	Total Coliform CFU/100mL	Background CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	---	18-Jan-06	18-Jan-06	18-Jan-06	18-Jan-06
2: Analysis Start Time		---	---	12:25	12:25	12:25	11:50
3: Analysis Approval Date		---	---	20-Jan-06	20-Jan-06	20-Jan-06	20-Jan-06
4: Analysis Approval Time		---	---	10:48	10:48	10:48	10:48
5: MAC		---	---	0	0	200	500
6: DW-Lot 48	17-Jan-06 09:05	5.0	0.5	0	0	0	10