

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100mL	Total Coliform CFU/100mL	Background CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	---	19-Oct-05	19-Oct-05	19-Oct-05	19-Oct-05
2: Analysis Start Time		---	---	16:50	16:50	16:50	13:15
3: Analysis Approval Date		---	---	24-Oct-05	24-Oct-05	24-Oct-05	24-Oct-05
4: Analysis Approval Time		---	---	08:44	08:44	08:44	08:44
5: MAC		---	---	0	0	200	500
6: DW-Lot 48	18-Oct-05 08:35	11.7	0.6	0	0	0	50