

ENVIRO-TEST ANALYTICAL REPORT

Sample Details/Parameters	Result	Qualifier	D.L.	Units	Extracted	Analyzed	By	Batch
L218279-1 ~D1 DISTRIBUTION								
Sample Date: 20-OCT-04 09:00								
Matrix: DISTRIBUTION								
Lead (Pb)	<1		1	ug/L		22-OCT-04		R231265
Trihalomethanes								
Chloroform	0.8		0.5	ug/L		21-OCT-04		R230553
Bromodichloromethane	1.2		0.5	ug/L		21-OCT-04		R230553
Dibromochloromethane	1.5		0.5	ug/L		21-OCT-04		R230553
Bromoform	<0.5		0.5	ug/L		21-OCT-04		R230553
Total THMs	4		2	ug/L		21-OCT-04		R230553
Surr: 1,2-Dichloroethane d4	118		87-127	%		21-OCT-04		R230553
NO2-N+NO3-N								
Nitrate and Nitrite as N	3.8		0.2	mg/L		22-OCT-04		
Nitrite-N								
Nitrite-N	<0.1		0.1	mg/L	21-OCT-04	21-OCT-04	TF	R230655
Nitrate-N								
Nitrate-N	3.8		0.1	mg/L	21-OCT-04	21-OCT-04	TF	R230655