

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	E.Coli CFU/100mL	Total Coliform CFU/100mL	Background CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	21-Sep-05	21-Sep-05	21-Sep-05	21-Sep-05
2: Analysis Start Time		---	14:20	14:20	14:20	12:50
3: Analysis Approval Date		---	26-Sep-05	26-Sep-05	26-Sep-05	26-Sep-05
4: Analysis Approval Time		---	08:37	08:37	08:37	08:37
5: MAC		---	0	0	200	500
6: DW-Lot 48	20-Sep-05 07:56	9.6	0	0	0	< 10