

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	E.Coli CFU/100mL	Total Coliform CFU/100mL	Background CFU/100 mL	HPC CFU/1mL Spread Plate
1: Analysis Start Date		---	---	30-Nov-05	30-Nov-05	30-Nov-05	30-Nov-05
2: Analysis Start Time		---	---	17:40	17:40	17:40	16:20
3: Analysis Approval Date		---	---	05-Dec-05	05-Dec-05	05-Dec-05	05-Dec-05
4: Analysis Approval Time		---	---	08:41	08:41	08:41	08:41
5: MAC		---	---	0	0	200	500
6: DW-Lot 48	29-Nov-05 08:28	7.9	0.6	0	0	0	< 10